



Government of West Bengal
Office of the Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo No.: FSR/211862406300006448

Date: 06-05-2025

From :
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To :
"The Biswas Educational Foundation" South Calcutta Public School
Mouza-Navason, JL No-109, LR Kh. No-772, RS Dag No-351 to 358 & 380, LR Dag No 374 to 381 & 403, Sonarpur, 24 Pgs(S)

Sub : Part Fire Safety Certificate for Occupancy of an existing Construction of G+III storied educational building having two blocks i.e existing G+I Storied East Block and G+III Storied West Block under group Educational building in the name and style of "SOUTH CALCUTTA PUBLIC SCHOOL UNDER THE BISWAS EDUCATIONAL FOUNDATION" establishment at Mouza-Navason, JL No-109, LR Kh. No-772, RS Dag No-351 to 354 & 356 to 358 & 380, LR Dag No 374 to 377 & 379 to 381, 403, Sonarpur, 24 Pgs(S) with in the jurisdiction of Pratapnagar Gram Panchayet.

This is in reference to your AIN 211892506300005717 dated 16-Mar-2025 regarding Part Fire Safety Certificate for Occupancy of an existing Construction of G+III storied educational building having two blocks i.e existing G+I Storied East Block and G+III Storied West Block under group Educational building in the name and style of "SOUTH CALCUTTA PUBLIC SCHOOL UNDER THE BISWAS EDUCATIONAL FOUNDATION" establishment at Mouza-Navason, JL No-109, LR Kh. No-772, RS Dag No-351 to 354 & 356 to 358 & 380, LR Dag No 374 to 377 & 379 to 381, 403, Sonarpur, 24 Pgs(S) with in the jurisdiction of Pratapnagar Gram Panchayet.

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

FSC approved with condition that, applicant shall obtain FSC for the entire building



South Calcutta Public School

Amit Singh
Manager

South Calcutta Public School

B. Samanta
Principal

The authenticity of this document can be verified by accessing the URL edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300005717

construction of two vertical floors.

1. Driveway must be maintained and free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed.
2. The Interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. specification.
3. To eliminate the risk of fire Hazards, Good House Keeping both for insides and outsides of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear & tear in them. Particularly lines above false ceiling & ducts.
5. A Fire Control room including a closed circuit T.V. system will have to be maintained which observes all floors of the building.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the building.
7. The employees and security staff shall be conversant with installed fire fighting equipment of the building and to operate in the event of the fire & testing.
8. Mock Fire Practice and Evacuation drill shall be performed periodically with participants of all the occupants of the building and record shall be kept in order.
9. Electrical mains, meter and panel room shall be protected with CO2 / D.C.P. Fire Extinction system confirming I.S. specification.
10. A trained fireman shall be maintained round the clock for safety of the building.
11. Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all the times.
12. If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
13. Periodical flashing of water from water based suppression system shall be made to maintain the efficient working performance of above mentioned system.
14. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
15. This Part Fire Safety Certificate is valid for Three (03) Years from date of issue of this memo and has to be renewal within stipulated periods.



South Calcutta Public School

Amit Singh
Manager

South Calcutta Public School

B. Samanta
Principal

The authenticity of this document can be verified by accessing the URL edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number: 211892506300005717

A certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building

Valid Upto : 04-May-2028

Form No. 123/2028/123456

South Calcutta Public School

Amit Singh
Manager

South Calcutta Public School

S. Samanta
Principal



Signature Not Verified

Digitally Signed
Name: ABHJIT PANDAY
Date: 04-May-2028 15:15:40
Reason: Signature Not Verified

Director

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300005717